



SYM	DATE	BY	REVISION	APP	XREF	REV	NOTES
H		MR		MR			1. CUTOUT IN GUARD TO BE UNDER FILL VALVE.
E		MR		MR			
F		MR		MR			
G		MR		MR			

SPECIFICATION	
O.D. 12	LGTH. 50
MAWP 312	PSI @ 650 °F
RT- MDMT -20 °F @ 312 PSI	GAL. 22.6
EXMT XRAY	TEST W
CRN M4739.5C	
WELD DETAILS: M-1932	
STD. TOLERANCES (UNLESS OTHERWISE NOTED): M-2461	

bed1\dwg\2000\

MOTORFUEL TANK

DRAWN BY: DPQ	DATE:	SCALE: NONE
APPR. BY: RM	DATE:	DRWG NO. 22987