


SYM	DATE	BY	REVISION	APP	NOTES
					1. REFER TO M-2566 FOR PLACEMENT OF 7/8\"/>

SPECIFICATIONS	
O.D. 11&1/2	LGTH. 40&4/0
MAMP 312	PSI @ 650 °F
RT- MDMT -20 °F @ 312 PSI	PSI
EXMT XRAY	TEST W
CRN M4506.5C	
WELD DETAILS: M-1932	
STD. TOLERANCES (UNLESS OTHERWISE NOTED): M-2461	



Q:\2000\

MOTORFUEL TANK

DRAWN BY: JR	DATE:	SCALE: NONE
APPR. BY: JR	DATE:	DWG NO. 270161