

PROUDLY MANUFACTURED IN THE USA



Aboveground Propane Tanks

superior quality unbeatable durability on-hand inventory



120-1000 GALLONS

PRESSURE VESSEL CODES & REGISTRATION

- Compliant with ASME/NBIC inspection standards
- Complies with NFPA 58
- Meets the specifications established by the Railroad Commission of Texas

PAINT SPECIFICATIONS

- Super durable polyester TGIC powder paint for maximum rust protection
- Standard tanks painted Sky White, additional colors available

VESSEL FEATURES

- Tanks fitted with Cavagna, Rotarex or RegO valves and Rochester or Rotarex liquid level gauges
- Container pressure rated at 250 PSI @ 400°F
- Vacuum purged
- Stainless steel data plate
- Plastic domes available

PROCESS CONTROL

All welded products are x-rayed and pressure tested @ 325 PSI per ASME Sec VIII, Div 1 requirements, followed by rigorous leak test inspections, both pre and post valving.

ABOVEGROUND PROPANE TANKS

Rev. 4/11/2025

Part Number	Water Capacity Gal/l	Outside Diameter In/mm	Head Type	Overall Length In/mm	Overall Height In/mm	Leg Width In/mm	Leg Spacing In/mm	Weight	Qua	Quantity	
Number								Lbs/kg	Full Load	Per Stack	
68268	120 454.2	24" 609.6	Ellip	5' 8" 1727.2	2' 10 1/4" 870	10 1/8" 257.2	3' 0" 914.4	302 137	96	12	
68270	250 946.3	30" 762	Hemi	7' 10" 2387.6	3' 4 3/16" 1020.8	12 3/4" 323.9	3' 6 " 1066.8	457 207.3	54	9	
68272	320 1211.3	30" 762	Hemi	9' 7" 2921	3' 4 3/16" 1020.8	12 3/4" 323.9	4' 1/4" 1225.6	563 255.4	45	9	
68303.20*	500 1892.7	41" 1041.4	Hemi	8' 8 1/2" 2654.3	3' 6 15/16" 1308.7	16 1/4" 412.8	3′ 8" 1117.6	972 440.9	30	5	
68304.20*	1000 3875.4	41" 1041.4	Hemi	15′ 8 1/2" 4787.9	3′ 6 15/16" 1308.7	16 1/4" 412.8	9' 0" 2743.2	1759 797.9	15	5	

* Drain

since 1946.

All Vessel Dimensions are Approximate

Federal, state, and local regulations may specify requirements for protective coatings and cathodic protection. The purchaser and installer are responsible for compliance with all relevant regulations, including proper purging before use. Continuous coatings are required and must adhere to applicable codes.

